TALTY WATER SUPPLY CORPORATION
PWS ID# 1290025
972-552-4422

CUSTOMER SERVICE INSPECTION CERTIFICATION

LOCATION OF SERVICE:_____

CUSTOMER NAME:_____ ACCOUNT NUMBER_____

Reason for Inspection: □ New Construction
□ Existing service where contaminant hazards are suspected
□ Major renovation or expansion of distribution facilities

I _____, upon inspection of the private plumbing facilities connected to the aforementioned public water supply do hereby certify that, to the best of my knowledge:

COMPLIANCE NON COMPLIANCE

_____ _____ (1) No direct connection between the public drinking water supply and a potential source or contamination exists. Potential sources of contamination are isolated from the public water system by an air gap or an appropriate backflow prevention assembly in accordance with state plumbing regulations. Additionally, all pressure relief valves and thermal expansion devises are in compliance with state plumbing codes.

_____ _____ (2) No cross-connection between the public drinking water supply and a private water system exists. Where an actual air gap is not maintained between the public water supply and a private water supply, an approved reduced pressure-zone backflow prevention assembly is properly installed and a service agreement exists for annual inspection and testing by a certified backflow prevention device tester.

_____ _____ (3) No connection exists which would allow the return of water used for condensing, cooling or industrial processes back to the public water supply.

_____ _____ (4) No pipe or pipe fitting which contains more than 8.0% lead exists in private plumbing facilities installed on or after July 1, 1988.

_____ _____ (5) No solder or flux which contains more than 0.2% lead exists in private plumbing facilities installed on or after July 1, 1988.

_____ _____ (6) No plumbing fixture is installed which is not in compliance with a state approved plumbing code.

Water service shall not be provided or restored to the private plumbing facilities until the above conditions are determined to be in compliance.

I further certify that the following materials were used in the installation of the plumbing facilities:

Service lines Lead ____ Copper ____ PVC ____ Other ____

Solder Lead ____ Lead Free ____ Solvent Weld ____ Other ____

I recognize that this document shall become a permanent record of the aforementioned Public Water System and that I am legally responsible for the validity of the information I have provided.

_____ _____
Signature of Inspector License Number

_____ _____
Title Type of License

_____
Date of Inspection